



Certificate of Continued Compliance 202350057/AA/00



Issued	15-02-2021	Replaces	
Expiry date	14-02-2025	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Q20 Capture wall mount quad PIR
Trademark:	Capture
Type designation:	AKCA0000
Serial No:	N/A
Hardware / Software:	AKCA0000 / FIR0164-2.3
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Texecom Ltd.
Address:	St. Crispin Way
City:	BB4 4PW HASLINGDEN
Country:	United Kingdom of Great Britain and Northern Ireland

This certificate is granted to:

Name of the certificate holder:	Texecom Ltd.
Address:	St. Crispin Way
City:	BB4 4PW HASLINGDEN
Country:	United Kingdom of Great Britain and Northern Ireland

Ron Scheepers
Managing director

This certificate has THREE Annexes.

CERTIFICATE

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Factory location:

Texecom Ltd

St Crispin Way

BB4 4PW, Haslingden

United Kingdom

Product inspection location:

JCL Logistics Benelux B.V.

Everdenberg 14

Oosterhout

The Netherland

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 200300038-001-Ver. 1.00, 25 January 2021
- Telefication B.V.: 200300047-001-Ver. 1.00, 25 January 2021
- Element Materials Technology: TSR-TRA-045950-35-00A_1__Emissions _ Susceptibility Test report for Capture P12, P15 Q15 and CQ__Doc_, 25 July 2019
- Element Materials Technology: TSR-TRA-045950-35-13A_1__Report on EMC Testing on Capture A20 with New Pyro__Doc_, 14 January 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2 November, 2017

Applied Standards

EN 50130-5 June, 2011
EN 50130-4+A1 October, 2014
EN 50131-1+A1+A2 May, 2017

The product as described in this certificate includes the following type designations

- Product description: Q20 Capture wall mount quad PIR
- Trademark: Capture
- Type designation: AKCA0000
- Hardware version: AKCA0000
- Software version: FIR0164-2.3
- Serial number: N/A

- Product description: CQ Capture Ceiling mount PIR
- Trademark: Capture
- Type designation: AKFA0000
- Hardware version: AKFA0000
- Software version: FIR0165-2.3
- Serial number: N/A