

DECLARATION OF CONFORMITY

We, **Cooper Fulleon Ltd,
Llantarnam Park,
Cwmbran, South Wales,
United Kingdom.
NP44 3AW**

declare under our sole responsibility that the product(s)

CXM & WP 24Vdc

(Fire Alarm Device –Manual Call Points for Fire Detection & Fire Alarm Systems)

Manufactured at the following site,

**Cooper Fulleon Ltd, Llantarnam Park, Cwmbran, South Wales, United Kingdom.
NP44 3AW**

or,

- 1. Digital Lighting (Dongguan) Co., Limited, Xin Min Road, Xin Min District, Changan Town, Dongguan City, Guangdong Province, China 523879**

is (are) in conformity with the following standard(s) or other normative document(s)

EN 61000-6-3 : 2007, EN 50130-4 : 2011 (EMC)

EN 50581:2012 (RoHS)

when used in the following applications & conditions:

Fire detection & Alarm Systems (Type A)

following the provisions of the directive(s):

EMC

2004/108/EC

2011/65/EU RoHS

10th April 2014

Date of Declaration



**Chris Anderson, Technical Director
Cooper Fulleon Limited**

Year of affixing the CE-marking: 2011